

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.88				Y
2	7.94				Y
3	7.98				Y
4	7.98				Y
5	7.96				Y
6	7.93				Y
7	7.91				Y
8	7.93				Y
9	7.96				Y
10	7.99				Y
11	8.00				Y
12	8.02				Y
13	8.03				Y
14	8.05				Y
15	8.02				Y
16	8.00				Y
17	7.98				Y
18	7.88				Y
19	7.77				Y
20	7.70				Y
21	7.72				Y
22	7.74				Y
23	7.75				Y
24	7.74				Y
25	7.72				Y
26	7.67				Y
27	7.63				Y
28	7.64				Y
29	7.69				Y
30	7.77				Y
31	7.78				Y

(No = N = Excursion) Total N's

0

<<Have minimums
been met for
this day?

ENTRY POINT

PWS ID: 41

0 0 0 7 4

System Name: Bandon, City of

Entry Point:

A

Sample Period:

Mar 2025

Number of excursions* during this month:

0

(Count the number of days when any WQP was less
than the minimum required)

Total excursions during the previous 5 months:

0

(Over 9 excursions in 6 months is a violation.
Entry Point and Distribution excursions are

For OHA

Minimum Water Quality
Parameters as set by

pH

7.1

ALK

(Alkalinity)

PO4

(Orthophosphate)

Other

()

Print Name: James Youravish

Signature:

Date:

4-2-2025

Send to DWP with 10 days after end of
sampling period