

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.79				Y
2	7.77				Y
3	7.78				Y
4	7.75				Y
5	7.72				Y
6	7.69				Y
7	7.66				Y
8	7.63				Y
9	7.61				Y
10	7.59				Y
11	7.57				Y
12	7.60				Y
13	7.63				Y
14	7.66				Y
15	7.66				Y
16	7.64				Y
17	7.66				Y
18	7.72				Y
19	7.79				Y
20	7.80				Y
21	7.79				Y
22	7.69				Y
23	7.61				Y
24	7.65				Y
25	7.75				Y
26	7.83				Y
27	7.85				Y
28	7.78				Y
29	7.66				Y
30	7.62				Y
31					
(No = N = Excursion) Total N's					0

<<Have minimums
been met for
this day?

ENTRY POINT

PWS ID: 41

0 0 0 7 4

System Name: Bandon, City of

Entry Point: A

Sample Period: April 2025
Month / Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less
than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation.
Entry Point and Distribution excursions are

For OHA

Minimum Water Quality
Parameters as set by

pH 7.1
ALK (Alkalinity)
PO4 (Orthophosphate)
Other ()

Print Name: James Youravish

Signature: [Signature]

Date: 5-2-2025

Send to DWP with 10 days after end of
sampling period