

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.64				Y
2	7.68				Y
3	7.70				Y
4	7.74				Y
5	7.81				Y
6	7.81				Y
7	7.72				Y
8	7.67				Y
9	7.65				Y
10	7.63				Y
11	7.64				Y
12	7.66				Y
13	7.65				Y
14	7.65				Y
15	7.63				Y
16	7.68				Y
17	7.73				Y
18	7.72				Y
19	7.64				Y
20	7.66				Y
21	7.67				Y
22	7.58				Y
23	7.49				Y
24	7.48				Y
25	7.46				Y
26	7.44				Y
27	8.06				Y
28	8.22				Y
29	8.09				Y
30	8.00				Y
31	7.96				Y
(No = N = Excursion) Total N's					0

<<Have minimums
been met for
this day?

ENTRY POINT

PWS ID: 41

0 0 0 7 4

System Name: Bandon, City of

Entry Point: A

Sample Period:

May 2025

Month / Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are

For OHA

Minimum Water Quality
Parameters as set by

pH

7.1

ALK

(Alkalinity)

PO4

(Orthophosphate)

Other

()

Print Name: James Youravishy

Signature: [Signature]

Date: 6-2-2025

Send to DWP with 10 days after end of sampling period