

## Lead & Copper Rule Corrosion Control

| Day | pH   | Alk | Phos | Other | Y/N |
|-----|------|-----|------|-------|-----|
| 1   | 7.95 |     |      |       | Y   |
| 2   | 7.95 |     |      |       | Y   |
| 3   | 7.94 |     |      |       | Y   |
| 4   | 7.93 |     |      |       | Y   |
| 5   | 7.93 |     |      |       | Y   |
| 6   | 7.92 |     |      |       | Y   |
| 7   | 7.92 |     |      |       | Y   |
| 8   | 7.91 |     |      |       | Y   |
| 9   | 7.90 |     |      |       | Y   |
| 10  | 7.90 |     |      |       | Y   |
| 11  | 7.89 |     |      |       | Y   |
| 12  | 7.83 |     |      |       | Y   |
| 13  | 7.75 |     |      |       | Y   |
| 14  | 7.69 |     |      |       | Y   |
| 15  | 7.70 |     |      |       | Y   |
| 16  | 7.66 |     |      |       | Y   |
| 17  | 7.65 |     |      |       | Y   |
| 18  | 7.65 |     |      |       | Y   |
| 19  | 7.75 |     |      |       | Y   |
| 20  | 7.83 |     |      |       | Y   |
| 21  | 7.83 |     |      |       | Y   |
| 22  | 7.75 |     |      |       | Y   |
| 23  | 7.57 |     |      |       | Y   |
| 24  | 7.78 |     |      |       | Y   |
| 25  | 8.03 |     |      |       | Y   |
| 26  | 8.01 |     |      |       | Y   |
| 27  | 7.95 |     |      |       | Y   |
| 28  | 7.91 |     |      |       | Y   |
| 29  | 7.88 |     |      |       | Y   |
| 30  | 7.88 |     |      |       | Y   |
| 31  |      |     |      |       |     |

(No = N = Excursion) Total N's

0

<<Have minimums  
been met for  
this day?

### ENTRY POINT

PWS ID: 41

0 0 0 7 4

System Name: Bandon, City of

Entry Point: A

Sample Period: June 2025  
Month / Year

Number of excursions\* during this month: 0  
(Count the number of days when any WQP was less  
than the minimum required)


Total excursions during the previous 5 months: 0  
(Over 9 excursions in 6 months is a violation.  
Entry Point and Distribution excursions are

For OHA

### Minimum Water Quality Parameters as set by

pH 7.1  
ALK      (Alkalinity)  
PO4      (Orthophosphate)  
Other      ( )

Print Name: James Youravish

Signature: 

Date: 7-8-2025

Send to DWP with 10 days after end of  
sampling period