



Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.80				Y
2	7.79				Y
3	7.70				Y
4	7.61				Y
5	7.55				Y
6	7.49				Y
7	7.41				Y
8	7.40				Y
9	7.44				Y
10	7.50				Y
11	7.59				Y
12	7.68				Y
13	7.74				Y
14	7.68				Y
15	7.66				Y
16	7.65				Y
17	7.61				Y
18	7.61				Y
19	7.65				Y
20	7.68				Y
21	7.69				Y
22	7.73				Y
23	7.79				Y
24	7.84				Y
25	7.77				Y
26	7.72				Y
27	7.74				Y
28	7.74				Y
29	7.70				Y
30	7.63				Y
31	7.57				Y
(No = N = Excursion) Total N's					0

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

System Name: Bandon, City of

Entry Point: A

Sample Period: Jan 2026
Month / Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are

For OHA

Minimum Water Quality Parameters as set by

pH (Alkalinity)
 ALK (Orthophosphate)
 PO4
 Other

Print Name: James Youravish

Signature:

Date: 12-31-2026

Send to DWP with 10 days after end of sampling period