



### Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.93				Y
2	7.99				Y
3	8.04				Y
4	8.08				Y
5	8.07				Y
6	8.04				Y
7	7.96				Y
8	7.93				Y
9	7.94				Y
10	7.97				Y
11	8.06				Y
12	8.16				Y
13	8.18				Y
14	8.12				Y
15	8.04				Y
16	7.96				Y
17	7.96				Y
18	7.95				Y
19	7.96				Y
20	8.03				Y
21	8.08				Y
22	8.09				Y
23	8.09				Y
24	8.13				Y
25	8.14				Y
26	8.08				Y
27	8.09				Y
28	8.11				Y
29	8.09				Y
30	8.05				Y
31	8.03				Y
(No = N = Excursion) Total N's					0

<<Have minimums been met for this day?

## ENTRY POINT

**PWS ID: 41**      0 0 0 7 4

**System Name:**      Bandon, City of

**Entry Point:**      A

**Sample Period:**      March 2026  
Month / Year


**Number of excursions\* during this month:** 0  
*(Count the number of days when any WQP was less than the minimum required)*

**Total excursions during the previous 5 months:** 0  
*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are*

For OHA

**Minimum Water Quality Parameters as set by**

pH      7.1  
 ALK        (Alkalinity)  
 PO4        (Orthophosphate)  
 Other        ( )

**Print Name:** James Youravish  
**Signature:**   
**Date:** 4-7-2026

Send to DWP with 10 days after end of sampling period