

Day	pH	Alk	Phos	Other	Y/N
1	7.7				
2	7.7				
3	7.5				
4	7.4				
5	7.5				
6	7.6				
7	7.7				
8	7.7				
9	7.7				
10	7.6				
11	7.6				
12	7.5				
13	7.6				
14	7.6				
15	7.7				
16	7.7				
17	7.7				
18	7.6				
19	7.6				
20	7.7				
21	7.6				
22	7.8				
23	7.8				
24	7.7				
25	8.0				
26	7.7				
27	7.8				
28	7.6				
29	7.7				
30	7.7				
31					

<<Have minimums been met for this day?

### ENTRY POINT

**PWS ID: 41**

0	0	0	7	9
---	---	---	---	---

**System Name:** Bay City Water System

**Entry Point:** Wells

**Sample Period:** 04/2022  
*Month/Year*

**Number of excursions\* during this month: 0**  
*(Count the number of days when any WQP was less than the minimum required)*

**Total excursions during the previous 5 months: 0**  
*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative )*

*For OHA use only*

**Minimum Water Quality Parameters as set by**

pH    

7.4
-----

Alk    

--

*(Alkalinity)*

PO4    

--

*(Orthophosphate)*

Other    

--

*(\_\_\_\_\_)*

**Print Name:** Brian Bettis

**Signature:** *B. Bettis*

**Date:** 05/04/2022

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) **Total N's**

--