

Day	pH	Alk	Phos	Other	Y/N
1	7.6				
2	7.5				
3	7.5				
4	7.6				
5	7.5				
6	7.5				
7	7.5				
8	7.4				
9	7.5				
10	7.4				
11	7.5				
12	7.6				
13	7.4				
14	7.4				
15	7.5				
16	7.4				
17	7.4				
18	7.4				
19	7.4				
20	7.5				
21	7.4				
22	7.4				
23	7.5				
24	7.6				
25	7.6				
26	7.7				
27	7.5				
28	7.6				
29	7.4				
30	7.5				
31	7.4				

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 0 0 0 7 9

System Name: Bay City Water System

Entry Point: Wells

Sample Period: July /2022
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)


Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	7.4	
Alk		(Alkalinity)
PO4		(Orthophosphate)
Other		(_____)

Print Name: Brian Bettis

Signature: 

Date: 08/03/2022

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0