

Day	pH	Alk	Phos	Other	Y/N
1	7.6				
2	7.6				
3	7.6				
4	7.6				
5	7.6				
6	7.6				
7	7.6				
8	7.6				
9	7.6				
10	7.7				
11	7.7				
12	7.7				
13	7.7				
14	7.7				
15	7.7				
16	7.5				
17	7.5				
18	7.5				
19	7.5				
20	7.5				
21	7.6				
22	7.5				
23	7.5				
24	7.5				
25	7.5				
26	7.5				
27	7.5				
28	7.5				
29	7.5				
30	7.5				
31	7.5				

<<Have minimums been met for this day?

**ENTRY POINT**

PWS ID: 41

0 0 0 7 9

System Name: Bay City Water System

Entry Point: Wells

Sample Period: January/2023

Month/Year

Number of excursions\* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative )

For OHA use only

**Minimum Water Quality Parameters as set by**

pH	7.4	
Alk		(Alkalinity)
PO4		(Orthophosphate)
Other		(_____)

Print Name: Brian Bettis

Signature: [Signature]

Date: 02/02/2023

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0