

Day	pH	Alk	Phos	Other	Y/N
1	7.5				
2	7.5				
3	7.5				
4	7.5				
5	7.6				
6	7.5				
7	7.5				
8	7.5				
9	7.6				
10	7.6				
11	7.5				
12	7.5				
13	7.5				
14	7.5				
15	7.6				
16	7.5				
17	7.5				
18	7.5				
19	7.5				
20	7.5				
21	7.5				
22	7.5				
23	7.6				
24	7.5				
25	7.5				
26	7.6				
27	7.6				
28	7.6				
29	7.6				
30	7.6				
31	7.6				
(No = N = Excursion) Total N's					0

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 0 0 0 7 9

System Name: Bay City Water System

Entry Point: Wells

Sample Period: February 2024
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by


pH 7.4

Alk (Alkalinity)

PO4 (Orthophosphate)

Other ()

Print Name: Brian Bettis

Signature: 

Date: 03/01/2024

Send to DWP within 10 days after end of sampling period