

Day	pH	Alk	Phos	Other	Y/N
1	7.5				
2	7.5				
3	7.4				
4	7.4				
5	7.4				
6	7.5				
7	7.5				
8	7.5				
9	7.5				
10	7.5				
11	7.5				
12	7.4				
13	7.4				
14	7.6				
15	7.6				
16	7.6				
17	7.6				
18	7.6				
19	7.6				
20	7.6				
21	7.65				
22	7.6				
23	7.65				
24	7.6				
25	7.6				
26	7.6				
27	7.6				
28	7.6				
29	7.6				
30	7.6				
31					

(No = N = Excursion) Total N's 0

<<Have minimums been met for this day? **ENTRY POINT**
PWS ID: 41

0	0	0	7	9
---	---	---	---	---

System Name: Bay City Water System
Entry Point: Wells
Sample Period: September 2024
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

7.4

Alk

--


 (Alkalinity)
PO4

--

 (Orthophosphate)
Other

--

 ()

Print Name: Brian Bettis
Signature: 
Date: 10/3/2024

Send to DWP within 10 days after end of sampling period