

Day	pH	Alk	Phos	Other	Y/N
1	7.7				
2	7.4				
3	7.6				
4	7.5				
5	7.4				
6	7.7				
7	7.9				
8	8.0				
9	7.6				
10	7.7				
11	7.7				
12	7.9				
13	7.9				
14	7.6				
15	7.8				
16	7.7				
17	7.7				
18	7.4				
19	7.6				
20	7.7				
21	7.7				
22	7.8				
23	7.8				
24	7.8				
25	7.4				
26	7.4				
27	7.4				
28	8.3				
29	7.4				
30	7.5				
31					
(No = N = Excursion) Total N's					0

<<Have minimums been met for this day?

**ENTRY POINT**

PWS ID: 41 

0	0	0	7	9
---	---	---	---	---

System Name: Bay City Water System

Entry Point: Wells

Sample Period: December 2024

*Month/Year*

Number of excursions\* during this month: 0  
*(Count the number of days when any WQP was less than the minimum required)*

Total excursions during the previous 5 months: 0  
*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative )*

*For OHA use only*

**Minimum Water Quality Parameters as set by**

pH	<table border="1" style="display: inline-table;"><tr><td>7.4</td></tr></table>	7.4	
7.4			
Alk	<table border="1" style="display: inline-table;"><tr><td> </td></tr></table>		<i>(Alkalinity)</i>
PO4	<table border="1" style="display: inline-table;"><tr><td> </td></tr></table>		<i>(Orthophosphate)</i>
Other	<table border="1" style="display: inline-table;"><tr><td> </td></tr></table>		<i>(_____)</i>

Print Name: Brian Bettis

Signature:

Date: 12/2/2024

Send to DWP within 10 days after end of sampling period