

Day	pH	Alk	Phos	Other	Y/N
1	7.9				
2	7.4				
3	7.7				
4	7.9				
5	7.6				
6	7.6				
7	7.6				
8	7.9				
9	7.9				
10	7.9				
11	7.8				
12	7.8				
13	8.1				
14	7.9				
15	7.9				
16	7.8				
17	8.0				
18	8.0				
19	8.1				
20	8.1				
21	8.0				
22	7.8				
23	7.4				
24	7.4				
25	7.8				
26	7.9				
27	7.7				
28	7.7				
29	7.8				
30	7.6				
31	7.6				
(No = N = Excursion) Total N's					0

<<Have

minimums
been met for
this day?

ENTRY POINT

PWS ID: 41

0 0 0 7 9

System Name: Bay City Water System

Entry Point: Wells

Sample Period: March 2025

Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was
less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry
Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.4

Alk (Alkalinity)

PO4 (Orthophosphate)

Other ()

Print Name: Brian Bettis

Signature: B. Bettis

Date: 04/02/2025

Send to DWP within 10 days after end of
sampling period