

Day	pH	Alk	Phos	Other	Y/N
1	7.7				
2	7.7				
3	7.7				
4	7.9				
5	7.9				
6	7.9				
7	7.8				
8	7.8				
9	7.7				
10	7.7				
11	7.7				
12	7.7				
13	7.7				
14	7.6				
15	7.9				
16	7.7				
17	7.7				
18	7.7				
19	7.7				
20	7.9				
21	7.9				
22	7.9				
23	7.9				
24	7.8				
25	7.6				
26	7.6				
27	7.6				
28	7.8				
29	8.3				
30	7.8				
31					

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41

0 0 0 7 9

System Name: Bay City Water System

Entry Point: Wells

Sample Period: april / 2025

Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was
less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry
Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

Alk

(Alkalinity)

PO4

(Orthophosphate)

Other

()

Print Name: Brian Bettis

Signature: B. Bettis

Date: 05/07/2025

Send to DWP within 10 days after end of
sampling period

(No = N = Excursion) Total N's

0