

Day	pH	Alk	Phos	Other	Y/N
1	7.4				
2	7.7				
3	7.8				
4	7.7				
5	7.8				
6	7.9				
7	7.9				
8	7.9				
9	7.6				
10	7.6				
11	7.6				
12	7.7				
13	7.9				
14	7.7				
15	7.6				
16	7.6				
17	7.9				
18	7.9				
19	7.8				
20	7.65				
21	7.6				
22	7.4				
23	7.6				
24	7.6				
25	7.6				
26	7.7				
27	7.9				
28	7.7				
29	7.7				
30	7.6				
31					

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41

0 0 0 7 9

System Name: Bay City Water System

Entry Point: Wells

Sample Period: 06/2025

Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was
less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry
Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.4
Alk (Alkalinity)
PO4 (Orthophosphate)
Other ()

Print Name: Brian Bettis

Signature: B. Bettis

Date: 07/02/2025

Send to DWP within 10 days after end of
sampling period

(No = N = Excursion) Total N's

0