

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.5				
2	7.5				
3	7.5				
4	7.5				
5	7.5				
6	7.5				
7	7.5				
8	7.5				
9	7.4				
10	7.4				
11	7.4				
12	7.5				
13	7.4				
14	7.5				
15	7.5				
16	7.5				
17	7.5				
18	7.5				
19	7.5				
20	7.4				
21	7.5				
22	7.6				
23	7.5				
24	7.5				
25	7.4				
26	7.4				
27	7.4				
28	7.4				
29	7.4				
30	7.4				
31					

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41

0 0 0 7 9

System Name: Bay City Water System

Entry Point: Wells

Sample Period: September / 2025
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was
less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry
Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality
Parameters as set by**

pH 7.4
Alk (Alkalinity)
PO4 (Orthophosphate)
Other ()

Print Name: Brian Bettis

Signature: B. Bettis

Date: 10/3/2025

Send to DWP within 10 days after end of
sampling period

(No = N = Excursion) Total N's 0