

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.5				
2	7.4				
3	7.8				
4	7.8				
5	7.8				
6	7.7				
7	7.5				
8	7.4				
9	7.6				
10	7.4				
11	7.5				
12	7.4				
13	7.5				
14	7.5				
15	7.6				
16	7.7				
17	7.5				
18	7.5				
19	7.5				
20	7.5				
21	7.6				
22	7.65				
23	7.5				
24	7.6				
25	7.6				
26	7.6				
27	7.6				
28	7.4				
29	7.5				
30	7.5				
31					

(No = N = Excursion) Total N's 0

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41

System Name: Bay City Water System

Entry Point: Wells

Sample Period: November / 2025

Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was
less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry
Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	7.4
Alk	 (Alkalinity)
PO4	 (Orthophosphate)
Other	 (_____)

Print Name: Brian Bettis

Signature: 

Date: 12/02/2025

Send to DWP within 10 days after end of
sampling period