

Day	pH	Alk	Phos	Other	Y/N
1	7.7				
2	7.4				
3	7.5				
4	7.8				
5	7.4				
6	7.4				
7	7.4				
8	7.1				
9	7.1				
10	7.6				
11	7.5				
12	7.4				
13	7.4				
14	7.4				
15	7.8				
16	7.6				
17	7.6				
18	7.5				
19	7.4				
20	7.6				
21	7.5				
22	7.4				
23	7.4				
24	7.8				
25	7.8				
26	7.9				
27	7.6				
28	7.6				
29	7.6				
30	7.8				
31	7.9				

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 0 0 0 7 9

System Name: Bay City Water System

Entry Point: Wells

Sample Period: 12/2025
Month/Year

Number of excursions* during this month: 2
(Count the number of days when any WQP was less than the minimum required)


Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	7.4	
Alk		<i>(Alkalinity)</i>
PO4		<i>(Orthophosphate)</i>
Other		<i>()</i>

Print Name: Brian Bettis

Signature: 

Date: 01/05/2026

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) **Total N's** 2