

Day	pH	Alk	Phos	Other	Y/N
1	7.6				
2	7.6				
3	7.4				
4	7.5				
5	7.4				
6	7.7				
7	7.6				
8	7.7				
9	7.6				
10	7.6				
11	7.6				
12	7.7				
13	7.4				
14	7.6				
15	7.6				
16	7.4				
17	7.7				
18	7.8				
19	7.6				
20	7.6				
21	7.6				
22	7.6				
23	7.6				
24	7.6				
25	7.6				
26	7.6				
27	7.6				
28	7.6				
29	7.6				
30	7.7				
31	7.6				

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

0	0	0	7	9
---	---	---	---	---

System Name: Bay City Water System

Entry Point: Wells

Sample Period: January 2021
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 1
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

7.4

Alk

--

(Alkalinity)

PO4

--

(Orthophosphate)

Other

--

(_____)

Print Name: Brian Bettis

Signature: 

Date: 02/04/2021

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's

0
