

Day	pH	Alk	Phos	Other	Y/N
1	7.6				
2	7.6				
3	7.6				
4	7.6				
5	7.6				
6	7.6				
7	7.6				
8	7.6				
9	7.6				
10	7.6				
11	7.6				
12	7.6				
13	7.6				
14	7.6				
15	7.6				
16	7.6				
17	7.6				
18	7.6				
19	7.6				
20	7.6				
21	7.6				
22	7.6				
23	7.6				
24	7.6				
25	7.6				
26	7.6				
27	7.6				
28	7.6				
29	7.6				
30	7.6				
31					
(No = N = Excursion) Total N's					0

<<Have minimums been met for this day?

**ENTRY POINT**

PWS ID: 41 

0	0	0	7	9
---	---	---	---	---

System Name: Bay City Water System

Entry Point: Wells

Sample Period: April 2021  
Month/Year

Number of excursions\* during this month: 0  
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative )

For OHA use only

**Minimum Water Quality Parameters as set by**

pH 

7.4
-----

Alk 

--

 (Alkalinity)

PO4 

--


 (Orthophosphate)

Other 

--

 (\_\_\_\_\_)

Print Name: Brian Bettis

Signature: 

Date: 05/04/2021

Send to DWP within 10 days after end of sampling period