

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
-----	----	-----	------	-------	-----

1	7.51				Y
2					
3					
4					
5					
6					
7					
8					
9					
10					
11					
12					
13					
14					
15	7.55				Y
16					
17					
18					
19					
20					
21					
22					
23					
24					
25					
26					
27					
28					
29	7.50				Y
30	7.47				Y
31					

(No = N = Excursion) **Total N's** 0

<<Have minimums been met for this day?

County: Washington

Agency: REGION 1

ENTRY POINT

EP-B

PWS ID 4100081

BEAVERTON, CITY OF



Sample period: June 2025
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality Parameter(s) as set by State:

pH 7.4

Print Name: Danielle Goodrich

Signature: Danielle Goodrich

Date & Phone#: 7/1/2025 503-616-8201

Send to DWP within 10 days after end of sampling period

DG1

7/28/2025