

Day	pH	Alk	Phos	Other	Y/N
-----	----	-----	------	-------	-----

1	7.49				Y
2					
3					
4					
5					
6					
7					
8					
9					
10					
11					
12					
13	7.53				Y
14	7.52				Y
15					
16					
17					
18					
19					
20					
21					
22					
23					
24					
25					
26					
27	7.50				Y
28					
29					
30					
31	7.50				Y

<<Have
minimums
been met for
this day?

County:
Washington

Agency: REGION 1

ENTRY POINT

EP-B

PWS ID 4100081

BEAVERTON, CITY OF

Sample period: July 2025
Month/Year

Number of excursions during this month: 0

*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative).
An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.*

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.4

Print Name: Danielle Goodrich

Signature: Danielle Goodrich

Date & Phone#: 8/6/2025 503-616-8201

Send to DWP within 10 days after end of
sampling period

(No = N = Excursion) **Total N's** 0