

## Water Quality Parameter Monitoring Form

## **Lead & Copper Rule Corrosion Control**

D #	Sample Location	рН	Alk	PO4	other	Y/N	<has sample<="" th=""></has>
1	9600 Sw Allen Blvd	8.28	36			Υ	met the <b>DISTRIBUTION</b> minimums?
2	12795 Sw 3rd St	8.01	36			Υ	
3	Sw 209th Ave	7.89	36			Υ	PWS ID: 41 0 0 0 8 1
4	11475 SW Center St	8.37	36			Υ	System Name: City of Beaverton
5	6110 SW Cape Meares Ct	8.05	30			Υ	Sample Period: February 2024  Month/Year
6	11750 SW Butte Ln	8.12	36			Υ	Sample Frequency: Monthly  Distribution Samples required: 10  Number of excursions during this  Sample Period = 0
7	7760 SW Raintree Dr	7.90				Υ	
8	9685 SW Buckskin Terr	7.86	28			Υ	
9	9255 SW Pinto Terr	7.87	37	19		Υ	
10	SW Cinnabar Ct	8.26	37		-	Υ	
11	10585 SW 161st Ct	8.59	33			Υ	(Number of locations when any WQP was less than the minimum.)
	11342 SW Meadowlark Ln	8.00	36			Υ	
13	15985 SW Nighthawk Dr	8.01				Υ	Note: Entry Point and Distribution
							Excursions are cumulative. Add Entry Point and Distribution Excursions to get total for sample period.
				-			
							For OHA use only
	· · · · · · · · · · · · · · · · · · ·			,			
							Minimum Water Quality
							Parameters as set by
							pH 7.2
						,	Alk (Alkalinity)
							PO4 (Orthophosphate)
		-		-		-	Other ()
		-		-			
		-		-			Print Name: Daniele Goodge
				<u> </u>			Signature: Death Signature
	(N = No = Exc	ursior	) <b>T</b>	otal N	's	0	Date: 5/9/24

Send to Drinking Water Program within 10 days after end of sampling period: OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405 Website: http://healthoregon.org/dwp/