



# Water Quality Parameter Monitoring Form

## Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	8.03				YES
2	7.87				YES
3	7.98				YES
4	7.27				YES
5	7.53				YES
6	7.51				YES
7	7.39				YES
8	8.60				YES
9	8.16				YES
10	8.00				YES
11	7.57				YES
12	7.76				YES
13	7.70				YES
14	7.42				YES
15	7.47				YES
16	7.29				YES
17	7.71				YES
18	7.42				YES
19	7.33				YES
20	7.84				YES
21	8.06				YES
22	8.68				YES
23	7.91				YES
24	8.17				YES
25	8.07				YES
26	7.75				YES
27	7.36				YES
28	7.22				YES
29	7.42				YES
30	7.52				YES
31	7.43				YES
(No = N = Excursion) Total N's					0

<<Have  
minimums  
been met  
for this day?

**ENTRY POINT**  
**A**

PWS ID: 4100152  
BROWNSVILLE, CITY OF

Sample Period: \_\_\_\_\_ Jul-21  
Month/Year

**Number of excursions\* during this month:** 0  
*(Count the number of days when any WQP was less than the minimum required)*


**Total excursions during the previous 5 months:** 0  
*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)*

**Is the system in compliance?** YES

*Reference*

**Minimum Water Quality Parameters as set by State:**

pH 7.2

Print Name: Karl Frink  
Signature:   
Date: 8-9-21

Send to OHD within 10 days after end of sampling period.