

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	рН	Alk	Phos	Sili	Y/N	< <have< th=""><th></th><th></th><th></th></have<>			
1	7.64				YES	minimums			
2	7.68				YES	been met ENTRY POINT		ENTRY POINT	
3	7.68				YES	for this day?		Α	
4	7.70				YES		<u>P\</u>	WS ID: 4100152	
5	7.68				YES	BROWNSVILLE, CITY OF			
6	7.54				YES				
7	7.57				YES	Sample	Period:	Sep-23	
8	7.53				YES			Month/Year	
9	7.58				YES				
10	7.57				YES	Number o	f excursions* d	uring this month:	0
11	7.57				YES	(Count the number of days when any WQP was less			
12	7.62				YES	than the minimum required)			
13	7.59				YES				
14	7.55				YES				
15	7.53				YES	Total exc	ursions during t	he previous 5 months:	0
16	7.56				YES	(Over 9 ex	(Over 9 excursions in 6 months is a violation. Entry		
17	7.58				YES	Point and	Point and Distribution excursions are cumulative)		
18	7.52				YES	Is the sys	Is the system in compliance?		YES
19	7.60				YES				
20	7.66				YES	Reference			
21	7.69				YES				
22	7.69				YES	l l	/linimum Wa	ater Quality	
23	7.77				YES	Pa	rameters as	s set by State:	
24	7.68				YES				
25	7.56				YES		рН 7.	2	
26	7.53				YES				
27	7.61				YES				
28	7.50				YES				
29	8.19				YES	Prir	ıt Name:	Karl Frink	
30	7.88				YES	Sig	gnature:	Karl Frink	
31							Date:	10/3/2023	
(No = 1	N = Exc	cursion		tal N's				ter end of sampling period.	

Oregon Health Division, PO Box 14350, Portland, OR 97293-0350 Phone (503) 731-4381