

Day	pH	Alk	Phos	Sili	Y/N	
1	7.37				YES	
2	7.24				YES	
3	7.22				YES	
4	7.31				YES	
5	7.50				YES	
6	7.53				YES	
7	7.41				YES	
8	7.33				YES	
9	7.38				YES	
10	7.44				YES	
11	7.55				YES	
12	7.56				YES	
13	7.48				YES	
14	8.55				YES	
15	7.80				YES	
16	7.51				YES	
17	8.00				YES	
18	7.27				YES	
19	7.39				YES	
20	7.62				YES	
21	7.29				YES	
22	7.32				YES	
23	7.26				YES	
24	7.43				YES	
25	7.24				YES	
26	7.69				YES	
27	7.36				YES	
28	7.42				YES	
29	7.37				YES	
30	7.36				YES	
31	7.43				YES	
					Total N's	0

<<Have
minimums
been met
for this day?

**ENTRY POINT
A**

PWS ID: 4100152

BROWNSVILLE, CITY OF

Sample Period: Mar-26
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

Is the system in compliance? YES

Reference

Minimum Water Quality Parameters as set by State:

pH 7.2

Print Name: Karl Frink
Signature: *Karl Frink*
Date: 4/2/2026

(No = N = Excursion)

Send to OHD within 10 days after end of sampling period.