



## Water Quality parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.51				Y
2	7.50				Y
3	7.45				Y
4	7.54				Y
5	7.39				Y
6	7.50				Y
7	7.52				Y
8	7.49				Y
9	7.46				Y
10	7.32				Y
11	7.46				Y
12	7.44				Y
13	7.50				Y
14	7.53				Y
15	7.51				Y
16	7.49				Y
17	7.52				Y
18	7.35				Y
19	7.51				Y
20	7.36				Y
21	7.45				Y
22	7.43				Y
23	7.47				Y
24	7.41				Y
25	7.46				Y
26	7.46				Y
27	7.50				Y
28	7.57				Y
29	7.50				Y
30	7.54				Y
31	7.63				Y
(No = N = Excursions) <b>Total N's</b>					<b>0</b>

<< Have  
minimums  
been met  
for this day?

<b>ENTRY POINT</b>	
PWS ID: 4100157	
	<b>CANBY UTILITY</b>
System Name:	
Entry Point:	A
Sample period:	Jan 2021
	Month / Year

**Number of excursions\* during this month:** 0  
*(Count the number of days when any WQP was less than the minimum required)*

**Total excursions during the previous 5 months:** 0  
*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)*

<p><b>Minimum Water Quality Parameters as set by State</b></p> <p style="font-size: 1.2em;">pH <span style="border: 1px solid black; padding: 2px 10px;">7.2</span></p>
---

Signature:   
 Facility DRC Dean Harvey #6980

Date: 02/08/2021