



Water Quality parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.65				Y
2	7.55				Y
3	7.51				Y
4	7.44				Y
5	7.44				Y
6	7.49				Y
7	7.56				Y
8	7.32				Y
9	7.54				Y
10	7.26				Y
11	7.58				Y
12	7.50				Y
13	7.38				Y
14	7.61				Y
15	7.57				Y
16	7.54				Y
17	7.51				Y
18	7.50				Y
19	7.37				Y
20	7.48				Y
21	7.52				Y
22	7.50				Y
23	7.55				Y
24	7.56				Y
25	7.52				Y
26	7.47				Y
27	7.48				Y
28	7.45				Y
29					
30					
31					
(No = N = Excursions) Total N's					0

<< Have
minimums
been met
for this day?

ENTRY POINT	
PWS ID: 4100157	
	CANBY UTILITY
System Name:	
Entry Point:	A
Sample period:	Feb 2021
	Month / Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

Minimum Water Quality Parameters as set by State	
pH	7.2

Signature:
 Facility DRC Dean Harvey #6980

Date: 3/8/2021