



Water Quality parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.34				Y
2	7.45				Y
3	7.30				Y
4	7.33				Y
5	7.49				Y
6	7.56				Y
7	7.61				Y
8	7.63				Y
9	7.49				Y
10	7.48				Y
11	7.50				Y
12	7.51				Y
13	7.51				Y
14	7.52				Y
15	7.42				Y
16	7.51				Y
17	7.54				Y
18	7.53				Y
19	7.53				Y
20	7.58				Y
21	7.58				Y
22	7.53				Y
23	7.51				Y
24	7.51				Y
25	7.58				Y
26	7.56				Y
27	7.56				Y
28	7.58				Y
29	7.60				Y
30	7.70				Y
31	7.45				Y
(No = N = Excursions) Total N's					0

<< Have
minimums
been met
for this day?

ENTRY POINT	
PWS ID: 4100157	
	CANBY UTILITY
System Name:	_____
Entry Point:	A
Sample period:	Jul 2021
	Month / Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

Minimum Water Quality Parameters as set by State	
pH	7.2

Signature:
 Facility DRC Dean Harvey #6980

Date: 8/4/2021

Send to DHS within 10 days after end of sampling period