



Water Quality parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.62				Y
2	7.72				Y
3	7.53				Y
4	7.53				Y
5	7.51				Y
6	7.55				Y
7	7.69				Y
8	7.69				Y
9	7.57				Y
10	7.49				Y
11	7.43				Y
12	7.49				Y
13	7.44				Y
14	7.44				Y
15	7.39				Y
16	7.43				Y
17	7.44				Y
18	7.41				Y
19	7.35				Y
20	7.35				Y
21	7.40				Y
22	7.41				Y
23	7.38				Y
24	7.52				Y
25	7.60				Y
26	7.43				Y
27	7.47				Y
28	7.34				Y
29	7.43				Y
30	7.39				Y
31					
(No = N = Excursions) Total N's					0

<< Have
minimums
been met
for this day?

ENTRY POINT	
PWS ID: 4100157	
	CANBY UTILITY
System Name:	
Entry Point:	A
Sample period:	Sep 2021
	Month / Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

Minimum Water Quality Parameters as set by State	
pH	7.2

Signature:
 Facility DRC Deah Harvey #6980

Date: 10/5/21

Send to DHS within 10 days after end of sampling period

DHS - Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (503) 731-4381