



## Water Quality parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.51				Y
2	7.65				Y
3	7.68				Y
4	7.59				Y
5	7.52				Y
6	7.73				Y
7	7.71				Y
8	7.71				Y
9	7.70				Y
10	7.66				Y
11	7.51				Y
12	7.52				Y
13	7.64				Y
14	7.78				Y
15	7.61				Y
16	7.37				Y
17	7.45				Y
18	7.42				Y
19	7.44				Y
20	7.50				Y
21	7.45				Y
22	7.50				Y
23	7.51				Y
24	7.65				Y
25	7.66				Y
26	7.42				Y
27	7.33				Y
28	7.39				Y
29	7.39				Y
30	7.36				Y
31					
(No = N = Excursions) Total N's					0

<< Have  
minimums  
been met  
for this day?

<b>ENTRY POINT</b>	
PWS ID: 4100157	
	<b>CANBY UTILITY</b>
System Name:	A
Entry Point:	Nov 2021
Sample period:	Month / Year

Number of excursions\* during this month: 0  
*(Count the number of days when any WQP was less than the minimum required)*

Total excursions during the previous 5 months: 0  
*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative )*

<p><b>Minimum Water Quality Parameters as set by State</b></p> <p>pH <span style="border: 1px solid black; padding: 2px 10px;">7.2</span></p>
---

Signature:   
 Facility DRC Dean Harvey #6980

Date: 12/8/21

Send to DHS within 10 days after end of sampling period