



## Water Quality parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.35				Y
2	7.61				Y
3	7.57				Y
4	7.45				Y
5	7.43				Y
6	7.48				Y
7	7.51				Y
8	7.51				Y
9	7.49				Y
10	7.51				Y
11	7.46				Y
12	7.52				Y
13	7.43				Y
14	7.42				Y
15	7.37				Y
16	7.51				Y
17	7.52				Y
18	7.56				Y
19	7.58				Y
20	7.58				Y
21	7.39				Y
22	7.47				Y
23	7.55				Y
24	7.60				Y
25	7.59				Y
26	7.48				Y
27	7.46				Y
28	7.43				Y
29	7.43				Y
30	7.45				Y
31	7.46				Y
(No = N = Excursions) Total N's					<b>0</b>

<< Have  
minimums  
been met  
for this day?

<b>ENTRY POINT</b>	
PWS ID: 4100157	
	<b>CANBY UTILITY</b>
System Name:	A
Entry Point:	Dec 2021
Sample period:	Month / Year

**Number of excursions\* during this month:** 0  
*(Count the number of days when any WQP was less than the minimum required)*

**Total excursions during the previous 5 months:** 0  
*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)*

<p><b>Minimum Water Quality Parameters as set by State</b></p> <p>pH <span style="border: 1px solid black; padding: 2px 10px;">7.2</span></p>
---

Signature:   
 Facility DRC Dean Harvey #6980

Date: 1/10/2022

Send to DHS within 10 days after end of sampling period