



Water Quality parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.45				Y
2	7.42				Y
3	7.44				Y
4	7.58				Y
5	7.70				Y
6	7.54				Y
7	7.51				Y
8	7.46				Y
9	7.42				Y
10	7.29				Y
11	7.39				Y
12	7.42				Y
13	7.42				Y
14	7.41				Y
15	7.35				Y
16	7.33				Y
17	7.41				Y
18	7.41				Y
19	7.44				Y
20	7.39				Y
21	7.44				Y
22	7.49				Y
23	7.52				Y
24	7.45				Y
25	7.49				Y
26	7.52				Y
27	7.55				Y
28	7.49				Y
29	7.49				Y
30	7.45				Y
31	7.44				Y
(No = N = Excursions) Total N's					0

<< Have
minimums
been met
for this day?

ENTRY POINT	
PWS ID: 4100157	
System Name:	
Entry Point:	A
Sample period:	Jan 2022
	Month / Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

<p>Minimum Water Quality Parameters as set by State</p> <p>pH 7.2</p>

Signature:
 Facility DRC Dean Harvey #6980

Date: 2/2/22