



Water Quality parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.50				Y
2	7.47				Y
3	7.51				Y
4	7.51				Y
5	7.37				Y
6	7.48				Y
7	7.38				Y
8	7.64				Y
9	7.50				Y
10	7.52				Y
11	7.47				Y
12	7.38				Y
13	7.41				Y
14	7.46				Y
15	7.49				Y
16	7.37				Y
17	7.40				Y
18	7.44				Y
19	7.54				Y
20	7.55				Y
21	7.64				Y
22	7.65				Y
23	7.68				Y
24	7.72				Y
25	7.63				Y
26	7.59				Y
27	7.56				Y
28	7.54				Y
29	7.46				Y
30	7.36				Y
31					
(No = N = Excursions) Total N's					0

<< Have
minimums
been met
for this day?

ENTRY POINT	
PWS ID: 4100157	
	CANBY UTILITY
System Name:	A
Entry Point:	Apr 2022
Sample period:	Month / Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

Minimum Water Quality Parameters as set by State	
pH	7.2

Signature:
 Facility DRC Dean Harvey #6980

Date: 5/3/22

Send to DHS within 10 days after end of sampling period