



## Water Quality parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.47				Y
2	7.53				Y
3	7.44				Y
4	7.45				Y
5	7.39				Y
6	7.49				Y
7	7.46				Y
8	7.45				Y
9	7.44				Y
10	7.50				Y
11	7.66				Y
12	7.72				Y
13	7.45				Y
14	7.51				Y
15	7.52				Y
16	7.51				Y
17	7.53				Y
18	7.58				Y
19	7.53				Y
20	7.48				Y
21	7.53				Y
22	7.46				Y
23	7.44				Y
24	7.40				Y
25	7.44				Y
26	7.47				Y
27	7.49				Y
28	7.42				Y
29	7.51				Y
30	7.50				Y
31	7.50				Y
(No = N = Excursions) Total N's					<b>0</b>

<< Have  
minimums  
been met  
for this day?

<b>ENTRY POINT</b>	
PWS ID: 4100157	
System Name:	
Entry Point:	A
Sample period:	May 2022
	Month / Year

Number of excursions\* during this month: 0  
*(Count the number of days when any WQP was less than the minimum required)*

Total excursions during the previous 5 months: 0  
*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)*

<b>Minimum Water Quality Parameters as set by State</b>	
pH	7.2

Signature:   
 Facility DRC Dean Harvey #6980

Date: 06/08/2022

Send to DHS within 10 days after end of sampling period

DHS - Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (503) 731-4381