



## Water Quality parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.52				Y
2	7.51				Y
3	7.53				Y
4	7.53				Y
5	7.53				Y
6	7.53				Y
7	7.53				Y
8	7.48				Y
9	7.43				Y
10	7.45				Y
11	7.43				Y
12	7.42				Y
13	7.43				Y
14	7.44				Y
15	7.44				Y
16	7.46				Y
17	7.46				Y
18	7.46				Y
19	7.50				Y
20	7.46				Y
21	7.36				Y
22	7.33				Y
23	7.33				Y
24	7.37				Y
25	7.39				Y
26	7.41				Y
27	7.43				Y
28	7.44				Y
29	7.45				Y
30	7.46				Y
(No = N = Excursions) <b>Total N's</b>					<b>0</b>

<< Have  
minimums  
been met .  
for this day?

**ENTRY POINT**  
PWS ID: 4100157

**CANBY UTILITY**

---

System Name: \_\_\_\_\_

---

Entry Point:           A          

---

Sample period:           Sep 2022            
  Month / Year

**Number of excursions\* during this month:**   6    
*(Count the number of days when any WQP was less than the minimum required)*

**Total excursions during the previous 5 months:**   6    
*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)*

**Minimum Water Quality  
Parameters as set by State**

pH 7.2

Signature: \_\_\_\_\_  
   Facility DRC    Dean Harvey #6980

Date:   10/4/2022  

Send to DHS within 10 days after end of sampling period  
 DHS - Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (503) 731-4381