



Water Quality parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.43				Y
2	7.41				Y
3	7.38				Y
4	7.43				Y
5	7.35				Y
6	7.35				Y
7	7.55				Y
8	7.57				Y
9	7.53				Y
10	7.55				Y
11	7.55				Y
12	7.55				Y
13	7.54				Y
14	7.53				Y
15	7.54				Y
16	7.47				Y
17	7.52				Y
18	7.52				Y
19	7.52				Y
20	7.51				Y
21	7.50				Y
22	7.42				Y
23	7.51				Y
24	7.50				Y
25	7.49				Y
26	7.48				Y
27	7.43				Y
28	7.34				Y
29	7.41				Y
30	7.38				Y
31	7.39				Y
(No = N = Excursions) Total N's					0

<< Have
minimums
been met
for this day?

ENTRY POINT	
PWS ID: 4100157	
	CANBY UTILITY
System Name:	A
Entry Point:	A
Sample period:	Oct 2022
	Month / Year

Number of excursions* during this month: _____
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

Minimum Water Quality Parameters as set by State	
pH	7.2

Signature: _____
 Facility DRC Dean Harvey #6980

Date: 11/2/22

Send to DHS within 10 days after end of sampling period