



Water Quality parameter Monitoring Form Lead & Copper Rule Corrosion Control

| Day | pH | Alk | Phos | Sili | Y/N |
|---------------------------------|------|-----|------|------|----------|
| 1 | 7.41 | | | | Y |
| 2 | 7.39 | | | | Y |
| 3 | 7.39 | | | | Y |
| 4 | 7.46 | | | | Y |
| 5 | 7.42 | | | | Y |
| 6 | 7.46 | | | | Y |
| 7 | 7.47 | | | | Y |
| 8 | 7.69 | | | | Y |
| 9 | 7.72 | | | | Y |
| 10 | 7.74 | | | | Y |
| 11 | 7.72 | | | | Y |
| 12 | 7.64 | | | | Y |
| 13 | 7.40 | | | | Y |
| 14 | 7.40 | | | | Y |
| 15 | 7.39 | | | | Y |
| 16 | 7.45 | | | | Y |
| 17 | 7.47 | | | | Y |
| 18 | 7.51 | | | | Y |
| 19 | 7.41 | | | | Y |
| 20 | 7.51 | | | | Y |
| 21 | 7.49 | | | | Y |
| 22 | 7.51 | | | | Y |
| 23 | 7.44 | | | | Y |
| 24 | 7.43 | | | | Y |
| 25 | 7.50 | | | | Y |
| 26 | 7.54 | | | | Y |
| 27 | 7.44 | | | | Y |
| 28 | 7.59 | | | | Y |
| 29 | 7.40 | | | | Y |
| 30 | 7.42 | | | | Y |
| 31 | 7.53 | | | | Y |
| (No = N = Excursions) Total N's | | | | | 0 |

<< Have
minimums
been met
for this day?

| | |
|--------------------|--------------------------|
| ENTRY POINT | |
| PWS ID: 4100157 | |
| | CANBY UTILITY |
| System Name: | A |
| Entry Point: | Dec 2022 |
| Sample period: | Month / Year |

Number of excursions* during this month: 4
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

| |
|---|
| <p>Minimum Water Quality Parameters as set by State</p> <p>pH 7.2</p> |
|---|

Signature:
 Facility DRC Dean Harvey #6980

Date: 1/5/23