



## Water Quality parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.53				Y
2	7.51				Y
3	7.42				Y
4	7.36				Y
5	7.30				Y
6	7.42				Y
7	7.49				Y
8	7.49				Y
9	7.59				Y
10	7.56				Y
11	7.52				Y
12	7.51				Y
13	7.53				Y
14	7.54				Y
15	7.51				Y
16	7.56				Y
17	7.52				Y
18	7.53				Y
19	7.57				Y
20	7.51				Y
21	7.49				Y
22	7.39				Y
23	7.41				Y
24	7.39				Y
25	7.32				Y
26	7.21				Y
27	7.33				Y
28	7.30				Y
29	7.35				Y
30	7.35				Y
31	7.34				Y
(No = N = Excursions) Total N's					<b>0</b>

<< Have  
minimums  
been met  
for this day?

<b>ENTRY POINT</b>	
PWS ID: 4100157	
System Name:	A
Entry Point:	Jan 2023
Sample period:	Month / Year

**Number of excursions\* during this month:** 0  
*(Count the number of days when any WQP was less than the minimum required)*

**Total excursions during the previous 5 months:** 0  
*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)*

<b>Minimum Water Quality Parameters as set by State</b>	
pH	7.2

Signature:   
 Facility DRC Dean Harvey #6980

Date: 2/4/23

Send to DHS within 10 days after end of sampling period