Water Quality parameter Monitoring Form

# Lead & Copper Rule Corrosion Control

| Day | pH | Alk | Phos | Sili | Y/N |
|---|---|---|---|---|---|
| 1 | 7.42 | | | | Y |
| 2 | 7.41 | | | | Y |
| 3 | 7.42 | | | | Y |
| 4 | 7.43 | | | | Y |
| 5 | 7.43 | | | | Y |
| 6 | 7.44 | | | | Y |
| 7 | 7.49 | | | | Y |
| 8 | 7.49 | | | | Y |
| 9 | 7.50 | | | | Y |
| 10 | 7.56 | | | | Y |
| 11 | 7.50 | | | | Y |
| 12 | 7.46 | | | | Y |
| 13 | 7.43 | | | | Y |
| 14 | 7.42 | | | | Y |
| 15 | 7.35 | | | | Y |
| 16 | 7.34 | | | | Y |
| 17 | 7.47 | | | | Y |
| 18 | 7.39 | | | | Y |
| 19 | 7.39 | | | | Y |
| 20 | 7.34 | | | | Y |
| 21 | 7.47 | | | | Y |
| 22 | 7.43 | | | | Y |
| 23 | 7.46 | | | | Y |
| 24 | 7.49 | | | | Y |
| 25 | 7.46 | | | | Y |
| 26 | 7.42 | | | | Y |
| 27 | 7.46 | | | | Y |
| 28 | 7.49 | | | | Y |
| 29 | 7.49 | | | | Y |
| 30 | 7.49 | | | | Y |
| 31 | | | | | |
| (No = N = Excursions) **Total N's** | | | | | **0** |

<< Have minimums been met for this day?

**ENTRY POINT**

PWS ID: 4100157

**System Name:** CANBY UTILITY

**Entry Point:** A

**Sample period:** Apr 2023

Month / Year

**Number of excursions* during this month:** Ø

*(Count the number of days when any WQP was less than the minimum required)*

**Total excursions during the previous 5 months:** Ø

*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative )*

**Minimum Water Qulity Parameters as set by State**

pH **7.2**

Signature: [signature]

Facility DRC Dean Harvey #6980

Date: 5/8/23

Send to DHS within 10 days after end of sampling period

DHS - Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (503) 731-4381