Water Quality parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.51				Y
2	7.44				Y
3	7.41				Y
4	7.48				Y
5	7.49				Y
6	7.52				Y
7	7.51				Y
8	7.51				Y
9	7.46				Y
10	7.42				Y
11	7.44				Y
12	7.42				Y
13	7.46				Y
14	7.45				Y
15	7.47				Y
16	7.48				Y
17	7.44				Y
18	7.47				Y
19	7.49				Y
20	7.51				Y
21	7.50				Y
22	7.49				Y
23	7.38				Y
24	7.44				Y
25	7.42				Y
26	7.49				Y
27	7.48				Y
28	7.46				Y
29	7.48				Y
30	7.46				Y
31					
(No = N = Excursions)				**Total N's**	**0**

<< Have minimums been met for this day?

ENTRY POINT

PWS ID: 4100157

System Name: CANBY UTILITY

Entry Point: A

Sample period: Jun 2023

Month / Year

Number of excursions* during this month: Ø

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: Ø

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

Minimum Water Qulity Parameters as set by State

pH **7.2**

Signature: [signature]

Facility DRC Dean Harvey #6980

Date: 7/1/2023

Send to DHS within 10 days after end of sampling period

DHS - Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (503) 731-4381