



Water Quality parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.51				Y
2	7.41				Y
3	7.39				Y
4	7.38				Y
5	7.44				Y
6	7.58				Y
7	7.58				Y
8	7.55				Y
9	7.49				Y
10	7.46				Y
11	7.49				Y
12	7.53				Y
13	7.52				Y
14	7.49				Y
15	7.43				Y
16	7.51				Y
17	7.52				Y
18	7.55				Y
19	7.48				Y
20	7.58				Y
21	7.60				Y
22	7.58				Y
23	7.37				Y
24	7.36				Y
25	7.42				Y
26	7.41				Y
27	7.42				Y
28	7.47				Y
29	7.47				Y
30	7.48				Y
31	7.53				Y
(No = N = Excursions) Total N's					0

<< Have
minimums
been met
for this day?

ENTRY POINT	
PWS ID: 4100157	
	CANBY UTILITY
System Name:	
Entry Point:	A
Sample period:	Aug 2023
	Month / Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

<p>Minimum Water Quality Parameters as set by State</p> <p style="font-size: 1.2em;">pH 7.2</p>

Signature:
 Facility DRC Dean Harvey #6980

Date: 9/5/2023

Send to DHS within 10 days after end of sampling period