



## Water Quality parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.38				Y
2	7.39				Y
3	7.44				Y
4	7.47				Y
5	7.46				Y
6	7.52				Y
7	7.48				Y
8	7.48				Y
9	7.52				Y
10	7.53				Y
11	7.51				Y
12	7.44				Y
13	7.49				Y
14	7.37				Y
15	7.35				Y
16	7.55				Y
17	7.45				Y
18	7.44				Y
19	7.48				Y
20	7.52				Y
21	7.43				Y
22	7.50				Y
23	7.51				Y
24	7.64				Y
25	7.56				Y
26	7.52				Y
27	7.47				Y
28	7.51				Y
29	7.44				Y
30	7.43				Y
31	7.45				Y
(No = N = Excursions) Total N's					0

<< Have minimums been met for this day?

**ENTRY POINT**

PWS ID: 4100157

System Name: \_\_\_\_\_

Entry Point:           A          

Sample period:           Jan 2024          

Month / Year

**Number of excursions\* during this month:**     0      
*(Count the number of days when any WQP was less than the minimum required)*

**Total excursions during the previous 5 months:**     0      
*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)*

**Minimum Water Quality Parameters as set by State**

pH 7.2

Signature:   
 Facility DRC    Dean Harvey #6980

Date:     02/06/24