



## Water Quality parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.46				Y
2	7.39				Y
3	7.41				Y
4	7.51				Y
5	7.45				Y
6	7.43				Y
7	7.47				Y
8	7.47				Y
9	7.46				Y
10	7.49				Y
11	7.49				Y
12	7.52				Y
13	7.52				Y
14	7.61				Y
15	7.44				Y
16	7.45				Y
17	7.46				Y
18	7.49				Y
19	7.55				Y
20	7.48				Y
21	7.47				Y
22	7.45				Y
23	7.42				Y
24	7.35				Y
25	7.35				Y
26	7.36				Y
27	7.42				Y
28	7.38				Y
29	7.38				Y
30	7.36				Y
31	7.53				Y
(No = N = Excursions) <b>Total N's</b>					<b>0</b>

<< Have  
minimums  
been met  
for this day?

<b>ENTRY POINT</b>	
PWS ID: 4100157	
	<b>CANBY UTILITY</b>
System Name:	_____
Entry Point:	A
Sample period:	Mar 2024
	Month / Year

**Number of excursions\* during this month:**   0    
*(Count the number of days when any WQP was less than the minimum required)*

**Total excursions during the previous 5 months:**   0    
*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)*

<b>Minimum Water Quality Parameters as set by State</b>	
pH	7.2

Signature:   
 Facility DRC Dean Harvey #6980

Date:   4/5/24  

Send to DHS within 10 days after end of sampling period