



Water Quality parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.37				Y
2	7.39				Y
3	7.39				Y
4	7.45				Y
5	7.44				Y
6	7.39				Y
7	7.37				Y
8	7.38				Y
9	7.42				Y
10	7.42				Y
11	7.46				Y
12	7.48				Y
13	7.48				Y
14	7.60				Y
15	7.63				Y
16	7.54				Y
17	7.47				Y
18	7.57				Y
19	7.55				Y
20	7.54				Y
21	7.53				Y
22	7.50				Y
23	7.55				Y
24	7.48				Y
25	7.48				Y
26	7.49				Y
27	7.39				Y
28	7.39				Y
29	7.37				Y
30	7.42				Y
31	7.41				Y
(No = N = Excursions) Total N's					0

<< Have minimums been met for this day?

ENTRY POINT

PWS ID: 4100157

System Name: _____

Entry Point: A

Sample period: May 2024

Month / Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

Minimum Water Quality Parameters as set by State

pH 7.2

Signature:
 Facility DRC Dean Harvey #6980

Date: 06/03/2024