

## Water Quality parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	рН	Alk	Phos	Sili	Y/N
1	7.37				Y
2	7.37				Y
3	7.27				Y
4	7.31				Y
5	7.46				Y
6	7.46				Y
7	7.44				Y
8	7.44				Y
9	7.42				Y
10	7.42				Y
11	7.31				Y
12	7.37				Y
13	7.35				Y
14	7.41				Y
15	7.33				Y
16	7.37				Y
17	7.40				Y
18	7.43				Y
19	7.41				Y
20	7.42				Y
21	7.45				Y
22	7.42				Y
23	7.41				Y
24	7.39				Y
25	7.54				Y
26	7.54				Y
27	7.49				Y
28	7.47				Y
29	7.47				Y
30	7.46				Y
31	7.53				Y
(No = N = Excursions)Total N's					0

<< Have					
minimums		ENTRY POINT			
been met		PWS ID: 4100157			
for this da	y? System Name:	SANBY			
	Entry Point:	A			
	Sample period:	Jul 2024			
		Month / Year			

Number of excursions\* during this month: (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 6 (Over 9 excursions in 6 months is a violation. Entry

Point and Distribution excursions are cumulative)

Minimum Water Qulity
Parameters as set by State

pH 7.2

Signature: Facility DRC Dean Harvey #6980

Date: 08/05/24

Send to DHS within 10 days after end of sampling period