



## Water Quality parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.52				Y
2	7.46				Y
3	7.46				Y
4	7.51				Y
5	7.50				Y
6	7.51				Y
7	7.48				Y
8	7.47				Y
9	7.46				Y
10	7.49				Y
11	7.54				Y
12	7.50				Y
13	7.44				Y
14	7.44				Y
15	7.52				Y
16	7.51				Y
17	7.49				Y
18	7.48				Y
19	7.51				Y
20	7.48				Y
21	7.50				Y
22	7.45				Y
23	7.42				Y
24	7.46				Y
25	7.47				Y
26	7.43				Y
27	7.48				Y
28	7.50				Y
29	7.49				Y
30	7.47				Y
31	7.46				Y
(No = N = Excursions) Total N's					<b>0</b>

<< Have  
minimums  
been met  
for this day?

**ENTRY POINT**  
PWS ID: 4100157

System Name: \_\_\_\_\_

Entry Point:           A          

Sample period:           Aug 2024            
Month / Year

**Number of excursions\* during this month:**           0            
*(Count the number of days when any WQP was less than the minimum required)*

**Total excursions during the previous 5 months:**           0            
*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative )*

**Minimum Water Quality  
Parameters as set by State**

pH 7.2

Signature:                       
Facility DRC    Dean Harvey #6980

Date:           9/10/24          

Send to DHS within 10 days after end of sampling period  
DHS - Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (503) 731-4381



## Water Quality parameter Monitoring Form Lead & Copper Rule Corrosion Control