



## Water Quality parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.48				Y
2	7.48				Y
3	7.41				Y
4	7.48				Y
5	7.54				Y
6	7.49				Y
7	7.50				Y
8	7.47				Y
9	7.46				Y
10	7.48				Y
11	7.47				Y
12	7.45				Y
13	7.49				Y
14	7.50				Y
15	7.48				Y
16	7.49				Y
17	7.46				Y
18	7.51				Y
19	7.54				Y
20	7.56				Y
21	7.60				Y
22	7.57				Y
23	7.46				Y
24	7.47				Y
25	7.54				Y
26	7.48				Y
27	7.50				Y
28	7.46				Y
29	7.44				Y
30	7.49				Y
31					
(No = N = Excursions) Total N's					0

<< Have  
minimums  
been met  
for this day?

<b>ENTRY POINT</b>	
PWS ID: 4100157	
	<b>CANBY UTILITY</b>
System Name:	_____
Entry Point:	A
Sample period:	Sep 2024
	Month / Year

**Number of excursions\* during this month:**   0    
*(Count the number of days when any WQP was less than the minimum required)*

**Total excursions during the previous 5 months:**   0    
*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative )*

<b>Minimum Water Quality Parameters as set by State</b>	
pH	7.2

Signature:   
 Facility DRC Dean Harvey #6980

Date: 10/01/2024

Send to DHS within 10 days after end of sampling period

DHS - Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (503) 731-4381