



Water Quality parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.42				Y
2	7.39				Y
3	7.40				Y
4	7.41				Y
5	7.42				Y
6	7.43				Y
7	7.43				Y
8	7.39				Y
9	7.50				Y
10	7.60				Y
11	7.50				Y
12	7.49				Y
13	7.51				Y
14	7.51				Y
15	7.36				Y
16	7.31				Y
17	7.38				Y
18	7.45				Y
19	7.51				Y
20	7.42				Y
21	7.35				Y
22	7.46				Y
23	7.49				Y
24	7.48				Y
25	7.58				Y
26	7.51				Y
27	7.54				Y
28	7.53				Y
29	7.53				Y
30	7.48				Y
31	7.45				Y
(No = N = Excursions) Total N's					0

<< Have
minimums
been met
for this day?

ENTRY POINT
PWS ID: 4100157

System Name: _____

Entry Point: A

Sample period: Dec 2024
Month / Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

**Minimum Water Quality
Parameters as set by State**

pH 7.2

Signature: *[Signature]*
Facility Manager Brain Hutchins #6660

Date: 1/9/2025