




Water Quality parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.49				Y
2	7.58				Y
3	7.62				Y
4	7.39				Y
5	7.39				Y
6	7.45				Y
7	7.49				Y
8	7.54				Y
9	7.47				Y
10	7.50				Y
11	7.56				Y
12	7.56				Y
13	7.53				Y
14	7.51				Y
15	7.53				Y
16	7.54				Y
17	7.52				Y
18	7.55				Y
19	7.47				Y
20	7.49				Y
21	7.46				Y
22	7.46				Y
23	7.45				Y
24	7.42				Y
25	7.35				Y
26	7.37				Y
27	7.40				Y
28	7.40				Y
29					
30					
31					
(No = N = Excursions)Total N's					0


<< Have
minimums
been met
for this day?

ENTRY POINT	
PWS ID: 4100157	
	
System Name:	
Entry Point:	A
Sample period:	Feb 2025
	Month / Year

Number of excursions* during this month: 4
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 4
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

Minimum Water Qulity Parameters as set by State pH 7.2
--

Signature: 
Facility DRC Dean Harvey #6980

Date: 03/03/2025

Send to DHS within 10 days after end of sampling period